

Bromine Test Kit

1 drop = 10 ppm / 10 mL

TK4995-Z

orange caps

KIT COMPONENTS:

SA1940-A	Sulfuric Acid 50%, 30 mL
PI1450-B	Potassium Iodide 50%, 60 mL
ST5010-B	Starch Indicator Solution 1%, 60 mL
ST2705-B	Sodium Thiosulfate 0.0365N, 60 mL
SY-2010-P	Syringe, 10 mL
VL-0525-V	Vial, 5-25 mL

INTERFERENCES: All oxidizers, including Chlorine, are positive interferences for this test. Interferences include, a pH over 8, Total Hardness over 1000 ppm, Sulfate over 1000 ppm, Total Alkalinity over 150 ppm, any concentration of Nitrite, Nitrate over 200 ppm, Silica Dioxide over 50 ppm, Copper over 10 ppm, any concentration of Ferrous Iron (Fe²⁺), and Ferric Iron (Fe³⁺) over 5 ppm.

SAFETY TIPS:



Wear
Gloves



Use Eye
Protection



Read
SDS

TESTING TIPS:



Collect
Accurate
Sample



Hold
Bottles
Vertically



Ensure
Proper
Lighting

ATTENTION: As necessary, calibrate this kit against a known standard made with plant / make-up water. Be sure to collect a representative sample.

It is important that each reagent be added and then mixed well for at least 5 seconds before the addition of the subsequent reagent.



Video Procedure




1 Rinse vial three times with sample to be tested. **Fill vial to 10 mL.**


Note: It is important that each reagent be added and then mixed well for at least 5 seconds before the addition of the subsequent reagent.

2 Add 10 drops of Potassium Iodide 50% (PI1450) and swirl 5 seconds to mix.

3 Add 10 drops of Starch Indicator 1% (ST5010) and swirl 5 seconds to mix.



STEP 1



STEP 3


4 Add 3 drops of Sulfuric Acid 50% (SA1940) one drop at a time while swirling. The sample will turn a blue-black color.



STEP 4

5 Add Sodium Thiosulfate 0.0365N (ST2705) one drop at a time while swirling. Count the number of drops until the sample returns to its original color.

of drops x 10 = ppm bromine



STEP 5